



TRENCH WIDTH NO LESS THAN 'PIPE DIAMETER + 300mm'
(Min. 150mm EITHER SIDE OF PIPE)

1.) ALTERNATIVELY, GRADED BACKFILL MATERIAL *ie* GRADED TO ELIMINATE STONES LARGER THAN 40mm, MAY BE USED FOR THE FIRST 300mm ABOVE CROWN OF PIPE. MECHANICAL COMPACTING IS PROHIBITED.

THIS DRAWING AND DETAILS CONTAINED WITHIN ARE COPYRIGHT OF G.R.&R.ROSS LTD. REPRODUCTION OR USE IS PROHIBITED WITHOUT WRITTEN PERMISSION.



ROSS ADT
30 BYRON STREET, DUNDEE DD3 6GX
Tel 01382 825050 Fax 01382 825100
e-mail info@rossadt.com

Drawn By	W Jackson	Date	26/03/04
Scale	1:10	Rev	00

Drawing No
AD800

Drawing Title
TYPICAL DETAIL: BACK-FILLING & BEDDING
(HDPE PIPEWORK)