



FOR PIPE DIAMETERS UP TO AND INCLUDING 160mm, FULL INTEGRITY OF FIRECOLLAR IS MAINTAINED FOR A MAXIMUM OF 240 MINUTES.

FOR PIPE DIAMETERS OF 200mm AND GREATER, FULL INTEGRITY OF FIRECOLLAR IS MAINTAINED FOR A MAXIMUM OF 180 MINUTES.

WALL FIXING: WHERE THERE IS RISK OF FIRE ON EITHER SIDE OF WALL, A FIRECOLLAR SHOULD BE FITTED IN EACH COMPARTMENT.

THIS DRAWING AND DETAILS CONTAINED WITHIN ARE COPYRIGHT OF G.R.&R.ROSS LTD. REPRODUCTION OR USE IS PROHIBITED WITHOUT WRITTEN PERMISSION.



ROSS ADT
30 BYRON STREET, DUNDEE DD3 6GX
Tel 01382 825050 Fax 01382 825100
e-mail info@rossadt.com

Drawn By	W Jackson	Date	05/08/04
Scale	n.t.s.	Rev	00

Drawing No
AD820

Drawing Title
**TYPICAL DETAIL:- FIRECOLLAR INSTALLATION,
SURFACE MOUNTING TO CONCRETE WALL/FLOOR**