



FOR ALL PIPE DIAMETERS, FULL INTEGRITY OF FIRECOLLAR IS MAINTAINED
FOR A MAXIMUM OF 120 MINUTES.

THIS DRAWING AND DETAILS CONTAINED WITHIN ARE COPYRIGHT OF G.R.&R.ROSS LTD.
REPRODUCTION OR USE IS PROHIBITED WITHOUT WRITTEN PERMISSION.

 <p>ROSS ADT 30 BYRON STREET, DUNDEE DD3 6GX Tel 01382 825050 Fax 01382 825100 e-mail info@rossad.com</p>		Drawn By	Date
		W Jackson	05/08/04
		Scale	Rev
		n.t.s.	00
Drawing Title		Drawing No	
TYPICAL DETAIL:- FIRECOLLAR INSTALLATION, SURFACE MOUNTING TO STUD PARTITION WALL		AD823	